

## Trapzilla® Solids Separator

# **TSS-95 Specifications**

#### PRODUCT FEATURES

Constructed of corrosion resistant materials suitable for installation in virtually any location.

Compact footprint.

Baffle structure retains separated solids permitting flow of grease, oil, and water.

Included lid rated for foot-traffic only.

### <u>SPECIFICATIONS</u>

Construction: Single-Piece Rotationally Molded


Polyethylene Exterior Tank with Inlet/ Outlet Inverts secured using Patented


Interior Radial Compression Ring


Flow Rating: \_ \_ 150 GPM (9.46 l/s)

Liquid Capacity: \_\_\_\_\_ 95 gallons (359 I) Solids Capacity: \_\_\_\_\_ 95 gallons (359 I)

Inlet/Outlet: \_\_\_\_\_ 4" (101 mm)







©2016 Thermaco, Inc. • All rights reserved • Patented/Patents Pending • Specifications subject to change without notice Thermaco, Inc. • PO Box 2548 • Asheboro, NC 27204-2548 • (336) 629-4651 • www.trapzilla.com



### Trapzilla® Solids Separator

## **TSS-95 Specifications**

#### **NOTES**

- 1. READ instruction manual included with system before installing/operating.
- 2. Unit requires 6" (15.24 cm) of clearance all the way around the lid from walls or other structures to allow for servicing.
- 3. Make piping connections with rubber "No Hub" connectors.
- 4. Keep outlet piping as straight as possible. Use only "sweep" connections.
- 5. Install vent on outlet piping.
- 6. If installing in conjunction with other Trapzilla products, include cleanout port before, after, and/or between each unit.
- 7. Do not install "P" Trap on outlet connection of tank (unit already has internal gas trap).
- 8. Do not reduce pipe size on outlet piping
- Do not pressure test unit.

Equipment must be installed in compliance with all applicable laws, regulations and codes, including plumbing codes. Installation should be performed by a qualified plumbing contractor.

#### JOB SPECIFICATION

Solids separator(s) shall be Thermaco Trapzilla solids interceptor system(s) as manufactured by Thermaco, Inc., Asheboro, North Carolina as noted on plans.

### **SEPARATOR SPECIFICATIONS**

Furnish and install	Thermaco Trapzilla Model No	o. TSS-95, rotationally m	nolded polyethylene solid	s separator(s) for
above or below ground in:	stallation, shall be rated at 150 gpm	n (9.46 l/s) with 95 gallo	ons (359 I) of total solids	storage capacity,
with removable cover for	solids removal access, integral anti	i-flotation anchor ring for	or in-ground installation,	laminar inlet flow
diverter, integral vessel ve	ent, a unitary tank body and 4" (101	mm) inlet/outlet structi	ures without gasket interf	aces, utilizing an
interior radial compression	n ring conjoining invert to tank outle	t/inlet structures withou	ıt bulkhead fittings and/or	gaskets, sloping
conical bottom, integral se	ewer gas trap, and a fully removable	polyethylene self-posit	tioning cover with sealed	thread fasteners.

SL	JBMITTAL OPTIONS
	6" (150mm) Inlet/Outlet - Model# TSS-95-6
	ECA-TSS-29 Extension Collar with additional 29" (73.7 cm) of extension
	TZSP-40-ECA Sampling Port with 4" Inlet/Outlet, 0.5" fall with 29" (73.7 cm) Extension Collar Assembly
	TZSP-48-ECA Sampling Port with 4" Inlet/Outlet, 7.8" fall with 29" (73.7 cm) Extension Collar Assembly
	VFCA-75 Vented Flow Control Assembly for installation at plumbing fixture level to limit flow to 75 gpm for installations wit head height greater than 6'
	MFSH-44 Molded Flow Splitter Assembly for evenly diverting flow to two separate 4" Trapzilla units
	MFSH-66 Molded Flow Splitter Assembly for evenly diverting flow to two separate 6" Trapzilla units
	FTCA-22 Fabricated Top Cover Assembly with 22" (55.9 cm) diameter diamond plate aluminum surface for heavy duty foot-traffic, pallet jacks, food carts etc. Replaces standard 22" STC-TZ-22 Cover (not rated for vehicle traffic)
	FTCA-36 Fabricated Top Cover Assembly with 36" (91.4 cm) diameter diamond plate aluminum surface for heavy duty foot-traffic, pallet jacks, food carts etc. Replaces Adapter Ring and Standard Cover (not rated for vehicle traffic)
	H20/Traffic Rated Installation, see <u>link</u> for installation drawings